

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading	
01/09/23 14:48	01/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.14	
02/09/23 14:48	02/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.68	
03/09/23 14:48	03/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.06	
04/09/23 14:48	04/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.99	
05/09/23 14:48	05/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.40	
06/09/23 14:48	06/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.95	
07/09/23 14:48	07/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.10	
08/09/23 14:48	08/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.98	
09/09/23 14:48	09/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.60	
10/09/23 14:48	10/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.76	
11/09/23 14:48	11/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.82	
12/09/23 14:48	12/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.98	
13/09/23 14:48	13/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.29	
14/09/23 14:48	14/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.47	
15/09/23 14:48	15/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.09	
16/09/23 14:48	16/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.14	
17/09/23 14:48	17/09/23 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.48	
23/09/23 14:42	23/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.46	

24/09/23 14:42	24/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.44
25/09/23 14:42	25/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.23
26/09/23 14:42	26/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.49
27/09/23 14:42	27/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.81
28/09/23 14:42	28/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.96
29/09/23 14:42	29/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.27
30/09/23 14:42	30/09/23 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.69

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

