



Visy Pulp and Paper Tumut CEMS - Correction Log

11/12/2023

Reporting Period: 1/11/2023 - 1/12/2023

Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Flow					
Period: 60 Minutes		Limit: 100.00 Nm3/s			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
08/11/23 12:00	08/11/23 13:00	Instrument Error	Normal (Steady State)	Group Instruments maintenance carried out on systems	100.98

Opacity					
Period: 6 Minutes		Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/11/23 15:36	01/11/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	27.00
02/11/23 15:36	02/11/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	28.84
03/11/23 15:36	03/11/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	27.43
04/11/23 15:36	04/11/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.44
05/11/23 15:36	05/11/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.07
06/11/23 15:36	06/11/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.86
10/11/23 15:30	10/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.72
11/11/23 15:30	11/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.00
12/11/23 15:30	12/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.29
13/11/23 15:30	13/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.16
14/11/23 15:30	14/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.00
15/11/23 15:30	15/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.09
16/11/23 15:30	16/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.31

17/11/23 15:30	17/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.05
18/11/23 15:30	18/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.96
19/11/23 15:30	19/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.58
20/11/23 15:30	20/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.81
21/11/23 15:30	21/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.46
22/11/23 15:30	22/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.35
23/11/23 15:30	23/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.73
24/11/23 15:30	24/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.10
25/11/23 15:30	25/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.43
26/11/23 15:30	26/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.88
27/11/23 15:30	27/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	27.03
28/11/23 15:30	28/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.29
29/11/23 15:30	29/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.33
30/11/23 15:30	30/11/23 15:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.80

Main Stack 2

Monitoring Location No: 22
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 2 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
24/11/23 18:00	24/11/23 18:18	Instrument Error	Equipment Issue/Failure	Heavy rain caused opacity measurement to malfunction.	21.24

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

