

## Main Stack 1

Monitoring Location No: 1  
 Monitoring Type: Continuous  
 Sample Type: Air  
 Description: Exit point from Stack 1 to atmosphere


Opacity						Period: 6 Minutes	Limit: 20.00 %
Start Time	End Time	Cause	Operational State	Explanation	Max Reading		
01/01/24 15:18	01/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.69		
02/01/24 15:18	02/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.66		
03/01/24 15:18	03/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.27		
04/01/24 15:18	04/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.42		
05/01/24 15:18	05/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.25		
06/01/24 15:18	06/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.60		
07/01/24 15:18	07/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.81		
08/01/24 15:18	08/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.16		
09/01/24 15:18	09/01/24 15:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.97		
10/01/24 09:18	10/01/24 09:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	29.07		
10/01/24 09:30	10/01/24 09:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.59		
11/01/24 09:30	11/01/24 09:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.01		
18/01/24 09:24	18/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.30		
19/01/24 09:24	19/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.79		
20/01/24 09:24	20/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.67		
21/01/24 09:24	21/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.89		
22/01/24 09:24	22/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.95		
23/01/24 09:24	23/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.27		

24/01/24 09:24	24/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.36
25/01/24 09:24	25/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.71
26/01/24 09:24	26/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.21
27/01/24 09:24	27/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.50
28/01/24 09:24	28/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.25
29/01/24 09:24	29/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.81
30/01/24 09:24	30/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.08
31/01/24 09:24	31/01/24 09:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.91

## Power Boiler

**Monitoring Location No:** 3  
**Monitoring Type:** Continuous  
**Sample Type:** Air  
**Description:** Discharge duct downstream of Power Boiler prior to junction with Stack 1

Nitrogen Oxides (as NO2)		Period: 60 Minutes	Limit: 300.00 mg/Nm3		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
18/01/24 09:00	18/01/24 10:00	Instrument Error	Normal (Steady State)	Instrument was worked on by Group Instruments.	349.59

Authorised By: **Uday Bhagwat**  
 Pulp Mill Manager  


**Johan Stoltz**  
 General Manager  
