



# Visy Pulp and Paper Tumut CEMS - Correction Log

5/04/2024

Reporting Period: 1/03/2024 - 1/04/2024

Environment Protection Licence No: 10232

## Main Stack 1

Monitoring Location No: 1  
 Monitoring Type: Continuous  
 Sample Type: Air  
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading	
01/03/24 09:18	01/03/24 09:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.45	
02/03/24 09:18	02/03/24 09:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.74	
07/03/24 09:12	07/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.51	
08/03/24 09:12	08/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.69	
09/03/24 09:12	09/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.09	
10/03/24 09:12	10/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.39	
11/03/24 09:12	11/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.82	
12/03/24 09:12	12/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.76	
13/03/24 09:12	13/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.69	
14/03/24 09:12	14/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.88	
15/03/24 09:12	15/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.69	
16/03/24 09:12	16/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.36	
17/03/24 09:12	17/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.02	
18/03/24 09:12	18/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.20	
19/03/24 09:12	19/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.52	
20/03/24 09:12	20/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.51	
21/03/24 09:12	21/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.60	
22/03/24 09:12	22/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.15	

23/03/24 09:12	23/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.59
24/03/24 09:12	24/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.50
25/03/24 09:12	25/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.87
26/03/24 09:12	26/03/24 09:18	Auto Zero Span Verification	Normal (Steady State)	We had an auto Calibration on the main stack and then the opacity took a long while to settle, we did not however have any exceedances during this time.	31.65
31/03/24 09:06	31/03/24 09:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.25

## Main Stack 2

**Monitoring Location No:** 22  
**Monitoring Type:** Continuous  
**Sample Type:** Air  
**Description:** Exit point from Stack 2 to atmosphere

Opacity					
Period: 6 Minutes		Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
04/03/24 11:24	04/03/24 11:30	Instrument Error	Normal (Steady State)	Calibrations done on Opacity measurement by Instrument maintenance department.	26.24
04/03/24 11:36	04/03/24 11:42	Instrument Error	Normal (Steady State)	Calibrations done on Opacity measurement by Instrument maintenance department.	22.48

Authorised By:

Uday Bhagwat  
Pulp Mill Manager

Johan Stoltz  
General Manager

*[Signature]*  
Ino Oliveira

*[Signature]*