

www.visy.com.au

Air Monitoring Data Report

The attached table summarises the results of emissions testing carried out on the Visy Gas Fired Boilers combined Discharge Stack for the 2022/23 Reporting Period.

Site:	Visy Paper Pty Ltd, Smithfield NSW	Licence No:	4100
Date of Test:	30 August 2023	Tester:	Ektimo Pty Ltd
Report No:	R011541	Report Date:	8 Sept 2023

Table 1: Summary of Average Emission Test Results (Report No. R012785)

Pollutant	Unit of measure	Concentration limit	Result	Compliance
Nitrogen dioxide	mg/m ³	250*	6.1	Yes
Nitric oxide	mg/m ³	250*	91	Yes
Oxygen	%	N/A	3.0	N/A
Temperature	°C	N/A	112	N/A
Velocity	m/s	N/A	4.8	N/A
Volumetric flow rate	m³/s	N/A	9.1	N/A
Dry gas density	kg/m³	N/A	1.33	N/A
Moisture	%	N/A	10	N/A
Molecular weight stack gases	g/gmol	N/A	29.8	N/A

All results comply with the Environmental Protection Licence emission limits.

Verified by:

Date: 11/09/2023

Ben Casauria Visy National Environment Manager