

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity					
Period: 6 Minutes		Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/06/24 07:54	01/06/24 08:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.54
02/06/24 07:54	02/06/24 08:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.20
03/06/24 07:54	03/06/24 08:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.74
04/06/24 07:54	04/06/24 08:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.22
05/06/24 07:54	05/06/24 08:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.64
11/06/24 07:48	11/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.17
12/06/24 07:48	12/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.18
13/06/24 07:48	13/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.06
14/06/24 07:48	14/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.75
15/06/24 07:48	15/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.47
16/06/24 07:48	16/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.05
17/06/24 07:48	17/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.08
18/06/24 07:48	18/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.57
19/06/24 07:48	19/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.99
20/06/24 07:48	20/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.39
21/06/24 07:48	21/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.15
22/06/24 07:48	22/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.81
23/06/24 07:48	23/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.40

24/06/24 07:48	24/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.42
25/06/24 07:48	25/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.38
26/06/24 07:48	26/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.31
27/06/24 07:48	27/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.79
28/06/24 07:48	28/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.96
29/06/24 07:48	29/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.65
30/06/24 07:48	30/06/24 07:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.16

Authorised By:

Uday Bhagwat
Pulp Mill Manager



J. Olivier

Johan Stoltz
General Manager


