



Visy Pulp and Paper Tumut CEMS - Correction Log

13/09/2024

Reporting Period: 1/08/2024 - 1/09/2024 Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/08/24 07:36	01/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.81
02/08/24 07:36	02/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.17
03/08/24 07:36	03/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.04
04/08/24 07:36	04/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.52
05/08/24 07:36	05/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.50
06/08/24 07:36	06/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.88
07/08/24 07:36	07/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.61
08/08/24 07:36	08/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.24
09/08/24 07:36	09/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.24
10/08/24 07:36	10/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	27.05
11/08/24 07:36	11/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.70
12/08/24 07:36	12/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.35
13/08/24 07:36	13/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.54
14/08/24 07:36	14/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.18
15/08/24 07:36	15/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.34
16/08/24 07:36	16/08/24 07:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.90
21/08/24 07:30	21/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.28
22/08/24 07:30	22/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.87

23/08/24 07:30	23/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.99
24/08/24 07:30	24/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.02
25/08/24 07:30	25/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.56
26/08/24 07:30	26/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.50
27/08/24 07:30	27/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.24
28/08/24 07:30	28/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.33
29/08/24 07:30	29/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.25
30/08/24 07:30	30/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.32
31/08/24 07:30	31/08/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.88

Main Stack 2


Monitoring Location No: 22
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 2 to atmosphere

Hydrogen Chloride (HCl) Period: 60 Minutes Limit: 50.00 mg/Nm3					
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
06/08/24 12:00	06/08/24 13:00	Instrument Error	Equipment Issue/Failure	Quarterly Maintenance was done by Lear Siegler on the system indicating an exceedance.	76.62
16/08/24 11:00	16/08/24 12:00	Instrument Error	Equipment Issue/Failure	RBB CEMS weekly maintenance done by E&I. (Checks and Calibration)	59.83

Nitrogen Oxides (as NO2) Period: 60 Minutes Limit: 400.00 mg/Nm3					
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
16/08/24 11:00	16/08/24 12:00	Instrument Error	Equipment Issue/Failure	RBB CEMS weekly maintenance done by E&I. (Checks and Calibration)	453.90

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

