

## Main Stack 1

Monitoring Location No: 1  
 Monitoring Type: Continuous  
 Sample Type: Air  
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/09/24 07:30	01/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.57
02/09/24 07:30	02/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.26
03/09/24 07:30	03/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.63
04/09/24 07:30	04/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.10
05/09/24 07:30	05/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.55
06/09/24 07:30	06/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	28.06
07/09/24 07:30	07/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.99
08/09/24 07:30	08/09/24 07:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.31
14/09/24 07:24	14/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.51
15/09/24 07:24	15/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.65
16/09/24 07:24	16/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.92
17/09/24 07:24	17/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.23
18/09/24 07:24	18/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.84
19/09/24 07:24	19/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.66
20/09/24 07:24	20/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.28
21/09/24 07:24	21/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.45
22/09/24 07:24	22/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.92
23/09/24 07:24	23/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.92

24/09/24 07:24	24/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.90
25/09/24 07:24	25/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.60
26/09/24 07:24	26/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.11
27/09/24 07:24	27/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.28
28/09/24 07:24	28/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.85
29/09/24 07:24	29/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.48
30/09/24 07:24	30/09/24 07:30	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.50

## Main Stack 2

Monitoring Location No: 22  
Monitoring Type: Continuous  
Sample Type: Air  
Description: Exit point from Stack 2 to atmosphere

Hydrogen Chloride (HCl)      Period: 60 Minutes      Limit: 50.00 mg/Nm3					
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/09/24 03:00	01/09/24 04:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	68.24

Opacity      Period: 6 Minutes      Limit: 20.00 %					
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
25/09/24 23:12	25/09/24 23:18	Instrument Error	Normal (Steady State)	Instrument drifted during heavy rain. Cause for this is under investigation	21.11

Authorised By:

Uday Bhagwat  
Pulp Mill Manager



Johan Stoltz  
General Manager

