

Ektimo

Visy Pulp and Paper, Tumut

Emission Testing Report – Q1 Testing (Odour)

Report R015496-1

ektimo.com.au



Accredited for compliance with ISO/IEC 17025 - Testing.
NATA is a signatory to the ILAC Mutual Recognition
Arrangement for the mutual recognition of the
equivalence of testing, calibration, and inspection reports.

Document Information

Client Name: Visy Pulp and Paper
Report Number: R015496-1
Date of Issue: 6 September 2023
Attention: Matthew O'Donovan
Address: 1302 Snowy Mountains Highway
Tumut NSW 2720
Testing Laboratory: Ektimo Pty Ltd, ABN 86 600 381 413

Report Authorisation

Aaron Davis
Operations Manager



NATA Accredited Laboratory
No. 14601

This document is confidential and is prepared for the exclusive use of Visy Pulp and Paper and those granted permission by Visy Pulp and Paper. The report shall not be reproduced except in full.

Please note that only numerical results pertaining to measurements conducted directly by Ektimo are covered by Ektimo terms of NATA accreditation as described in the Test Methods table. This does not include calculations that use data supplied by third-parties, comments, conclusions, or recommendations based upon the results. Refer to Test Methods section for full details of testing covered by NATA accreditation.

Table of Contents

- 1 Executive Summary4
- 1.1 Background4
- 1.2 Project Objective & Overview4
- 2 Results5
- 2.1 EPA 1 – Main Stack 1.....5
- 2.2 EPA 22 – Main Stack 2.....6
- 2.3 Cooling Pond 3A.....7
- 2.4 Cooling Pond 3B.....8
- 2.5 Vacuum Pump 3 – (790 Couch).....9
- 2.6 Vacuum Pump 7 – (794 First Bottom).....10
- 2.7 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust).....11
- 2.8 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust).....12
- 3 Sample Plane Compliance13
- 3.1 EPA 1 – Main Stack 1.....13
- 3.2 EPA 22 – Main Stack 2.....13
- 3.3 Vacuum Pump 3 – (790 Couch).....13
- 3.4 Vacuum Pump 7 – (794 First Bottom).....14
- 3.5 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust).....14
- 3.6 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust).....15
- 4 Plant Operating Conditions15
- 5 Test Methods16
- 6 Quality Assurance/Quality Control Information16
- 7 Definitions17
- 8 Appendices18

Appendix A: Site Images

1 Executive Summary

1.1 Background

Ektimo was engaged by Visy Pulp and Paper to perform an odour monitoring survey at their Tumut facility. The program incorporated both point source and area source (flux hood) monitoring.

1.2 Project Objective & Overview

The objective of the project was to conduct a monitoring program to quantify emissions from multiple discharge points.

Monitoring was performed as follows:

Location	Test Date	Test Parameters*
EPA 1 – Main Stack 1	16 August 2023	Odour (duplicate)
EPA 22 – Main Stack 2		
Cooling Pond 3A		
Cooling Pond 3B		
Cooling Tower 1 (#1 Paper Machine Side)**		
Cooling Tower 2 (#2 Paper Machine Side)**		
Vacuum Pump 3 – (790 Couch)		
Vacuum Pump 7 – (794 First Bottom)		
Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)		
Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)		

* Flow rate, velocity, temperature, and moisture were also determined.

** Access to sampling locations was unavailable due to safety concerns.

All results are reported on a dry basis at STP (except odour wet – STP).

Note that odour sampling and analysis is typically conducted on emissions from Cooling Tower 1 and 2 (Paper Machine Side). On this occasion monitoring could not be performed due to temporary restricted access to the sampling locations.

2 Results

2.1 EPA 1 – Main Stack 1

Date	16/08/2023	Client	Visy Pulp and Paper
Report	R015496	Stack ID	EPA 1 - Main Stack 1
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Ahmad Ramiz	State	NSW
Process Conditions	Please refer to client records		230814

Stack Parameters		
Moisture content, %v/v	21	
Gas molecular weight, g/g mole	28.0 (wet)	30.8 (dry)
Gas density at STP, kg/m ³	1.25 (wet)	1.37 (dry)
Gas density at discharge conditions, kg/m ³	0.70	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	0930	
Temperature, °C	196	
Temperature, K	469	
Velocity at sampling plane, m/s	30	
Volumetric flow rate, actual, m ³ /s	160	
Volumetric flow rate (wet STP), m ³ /s	92	
Volumetric flow rate (dry STP), m ³ /s	72	
Mass flow rate (wet basis), kg/h	410000	

Odour	Sampling time	Average		Test 1 0935 - 0940		Test 2 0942 - 0952	
		Odourant Flow		Odourant Flow		Odourant Flow	
		Concentration ou	Rate ou.m ³ /min	Concentration ou	Rate ou.m ³ /min	Concentration ou	Rate ou.m ³ /min
Results		1100	5900000	1100	6200000	1000	5700000
Lower uncertainty limit		860		830		760	
Upper uncertainty limit		1300		1500		1400	
Analysis date & time				17/08/23, 1000 - 1245		17/08/23, 1000 - 1245	
Holding time				25 hours		24 hours	
Dilution factor				1		1	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		58					
Laboratory temp (°C)		22					
Last calibration date		October 2022					

2.2 EPA 22 – Main Stack 2

Date	16/08/2023	Client	Visy Pulp and Paper
Report	R015496	Stack ID	EPA 22 - Main Stack 2
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Ahmad Ramiz	State	NSW
Process Conditions	Please refer to client records		230814

Stack Parameters		
Moisture content, %v/v	19	
Gas molecular weight, g/g mole	28.2 (wet)	30.7 (dry)
Gas density at STP, kg/m ³	1.26 (wet)	1.37 (dry)
Gas density at discharge conditions, kg/m ³	0.73	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	0830	
Temperature, °C	179	
Temperature, K	452	
Velocity at sampling plane, m/s	22	
Volumetric flow rate, actual, m ³ /s	100	
Volumetric flow rate (wet STP), m ³ /s	59	
Volumetric flow rate (dry STP), m ³ /s	48	
Mass flow rate (wet basis), kg/h	270000	

Odour	Sampling time	Average		Test 1 0835 - 0845		Test 2 0847 - 0857	
		Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min
Results		590	2100000	660	2400000	510	1800000
Lower uncertainty limit		470		490		380	
Upper uncertainty limit		730		900		690	
Analysis date & time				17/08/23, 1000 - 1245		17/08/23, 1000 - 1245	
Holding time				26 hours		25 hours	
Dilution factor				1		1	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		58					
Laboratory temp (°C)		22					
Last calibration date		October 2022					

2.3 Cooling Pond 3A

Client	Visy Pulp and Paper	Test Location	Cooling Pond 3A
Date	16/08/2023	Plant/Site	Tumut
Report No.	R015496		Tumut, NSW
Ektimo Staff	Aaron Davis / Ahmad Ramiz		220907
Test Location Details			
Location Description	Blackish, brown murky liquid, not filling		
Surface Description	Clear surface, aerating		
Area Classification	Industrial		
Source dimensions (L x W), m	50 x 32		
Source area, m ²	1600		
Sampling Method	AS4323.4 (Flux)		
Odour			
	Test 1	Test 2	
Sampling time, hrs	0855 - 0905	0905 - 0915	
Sample dilution	1	1	
Concentration, ou	44	<30	
Average concentration, ou	≤39		
95% Confidence Interval	31 - 49		
Flux Emission Rate, ou.m³/m²/min	≤1.4		
Total area source emission rate, ou.m³/min	≤2300		
Flux Testing Parameters			
Equilibration time, hrs	0830 - 0854		
Sweep Rate @ STP, L/min	4.67		
Penetration Depth, mm	10		
Static Pressure, Pa	10		
Surface temperature, °C	10		
Chamber temperature, °C	13		
Ambient temperature, °C	10		

2.4 Cooling Pond 3B

Client	Visy Pulp and Paper	Test Location	Cooling Pond 3B
Date	16/08/2023	Plant/Site	Tumut
Report No.	R015496		Tumut, NSW
Ektimo Staff	Aaron Davis / Ahmad Ramiz		220907
Test Location Details			
Location Description	Brown murky liquid, filling up		
Surface Description	Foamy, white		
Area Classification	Industrial		
Source dimensions (L x W), m	50 x 32		
Source area, m ²	1600		
Sampling Method	AS4323.4 (Flux)		
Odour			
	Test 1	Test 2	
Sampling time, hrs	0942 - 0952	0952 - 1002	
Sample dilution	1	1	
Concentration, ou	81	63	
Average concentration, ou	72		
95% Confidence Interval	58 - 90		
Flux Emission Rate, ou.m³/m²/min	2.6		
Total area source emission rate, ou.m³/min	4200		
Flux Testing Parameters			
Equilibration time, hrs	0918 - 0942		
Sweep Rate @ STP, L/min	4.58		
Penetration Depth, mm	10		
Static Pressure, Pa	20		
Surface temperature, °C	14		
Chamber temperature, °C	17		
Ambient temperature, °C	13		

2.5 Vacuum Pump 3 – (790 Couch)

Date	16/08/2023	Client	Visy Pulp and Paper
Report	R015496	Stack ID	Vacuum Pump 3 (790 Couch)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Ahmad Ramiz	State	NSW
Process Conditions	Please refer to client records.		

230825

Comments

The discharge is assumed to be composed of dry air and moisture

Stack Parameters

Moisture content, %v/v	13 (saturated)	
Gas molecular weight, g/g mole	27.6 (wet)	29.0 (dry)
Gas density at STP, kg/m ³	1.23 (wet)	1.29 (dry)
Gas density at discharge conditions, kg/m ³	1.00	

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1255
Temperature, °C	50
Temperature, K	323
Velocity at sampling plane, m/s	7.5
Volumetric flow rate, actual, m ³ /s	6
Volumetric flow rate (wet STP), m ³ /s	4.8
Volumetric flow rate (dry STP), m ³ /s	4.2
Mass flow rate (wet basis), kg/h	21000

Odour	Sampling time	Average		Test 1		Test 2	
		Odourant Flow		1300 - 1302		1305 - 1307	
		Concentration	Rate	Concentration	Rate	Concentration	Rate
		ou	ou.m ³ /min	ou	ou.m ³ /min	ou	ou.m ³ /min
Results		9500	2800000	12000	3600000	6700	1900000
Lower uncertainty limit		7700		9100		4900	
Upper uncertainty limit		12000		17000		9100	
Analysis date & time				17/08/23, 1000 - 1245		17/08/23, 1000 - 1245	
Holding time				21 hours		21 hours	
Dilution factor				5		5	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		58					
Laboratory temp (°C)		22					
Last calibration date		October 2022					

2.6 Vacuum Pump 7 – (794 First Bottom)

Date	16/08/2023	Client	Visy Pulp and Paper
Report	R015496	Stack ID	Vacuum Pump 7 (794 First Bottom)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Ahmad Ramiz	State	NSW
Process Conditions	Please refer to client records.		

230825

Comments

The discharge is assumed to be composed of dry air and moisture

Stack Parameters

Moisture content, %v/v	12 (saturated)	
Gas molecular weight, g/g mole	27.6 (wet)	29.0 (dry)
Gas density at STP, kg/m ³	1.23 (wet)	1.29 (dry)
Gas density at discharge conditions, kg/m ³	1.00	

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1220
Temperature, °C	49
Temperature, K	322
Velocity at sampling plane, m/s	7
Volumetric flow rate, actual, m ³ /s	4.5
Volumetric flow rate (wet STP), m ³ /s	3.7
Volumetric flow rate (dry STP), m ³ /s	3.2
Mass flow rate (wet basis), kg/h	16000

Odour	Sampling time	Average		Test 1 1225 - 1227		Test 2 1230 - 1232	
		Odourant Flow		Odourant Flow		Odourant Flow	
		Concentration	Rate	Concentration	Rate	Concentration	Rate
		ou	ou.m ³ /min	ou	ou.m ³ /min	ou	ou.m ³ /min
Results		32000	7000000	35000	7700000	29000	6400000
Lower uncertainty limit		26000		26000		21000	
Upper uncertainty limit		40000		47000		39000	
Analysis date & time				17/08/23, 1000 - 1245		17/08/23, 1000 - 1245	
Holding time				22 hours		22 hours	
Dilution factor				9		9	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		58					
Laboratory temp (°C)		22					
Last calibration date		October 2022					

2.7 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)

Date	16/08/2023	Client	Visy Pulp and Paper
Report	R015496	Stack ID	Vacuum Pump 9
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Ahmad Ramiz	State	NSW
Process Conditions	Please refer to client records.		

230825

Comments
The discharge is assumed to be composed of dry air and moisture

Stack Parameters		
Moisture content, %v/v	26 (saturated)	
Gas molecular weight, g/g mole	26.1 (wet)	29.0 (dry)
Gas density at STP, kg/m ³	1.17 (wet)	1.29 (dry)
Gas density at discharge conditions, kg/m ³	0.90	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	1240	
Temperature, °C	65	
Temperature, K	338	
Velocity at sampling plane, m/s	8.8	
Volumetric flow rate, actual, m ³ /s	23	
Volumetric flow rate (wet STP), m ³ /s	18	
Volumetric flow rate (dry STP), m ³ /s	13	
Mass flow rate (wet basis), kg/h	75000	

Odour	Sampling time	Average		Test 1		Test 2	
		Odourant Flow		1245 - 1247		1250 - 1252	
		Concentration	Rate	Concentration	Rate	Concentration	Rate
Results		ou	ou.m ³ /min	ou	ou.m ³ /min	ou	ou.m ³ /min
		2900	3200000	3300	3600000	2600	2800000
Lower uncertainty limit		2400		2400		1900	
Upper uncertainty limit		3600		4500		3500	
Analysis date & time				17/08/23, 1000 - 1245		17/08/23, 1000 - 1245	
Holding time				22 hours		21 hours	
Dilution factor				5		5	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		58					
Laboratory temp (°C)		22					
Last calibration date		October 2022					

2.8 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)

Date	16/08/2023	Client	Visy Pulp and Paper
Report	R015496	Stack ID	Vacuum Pump 10
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Ahmad Ramiz	State	NSW
Process Conditions	Please refer to client records.		230825

Comments
The discharge is assumed to be composed of dry air and moisture

Stack Parameters			
Moisture content, %v/v	8 (saturated)		
Gas molecular weight, g/g mole	28.1 (wet)	29.0 (dry)	
Gas density at STP, kg/m ³	1.25 (wet)	1.29 (dry)	
Gas density at discharge conditions, kg/m ³	1.05		
Gas Flow Parameters			
Flow measurement time(s) (hhmm)	1310		
Temperature, °C	41		
Temperature, K	314		
Velocity at sampling plane, m/s	3.5		
Volumetric flow rate, actual, m ³ /s	30		
Volumetric flow rate (wet STP), m ³ /s	25		
Volumetric flow rate (dry STP), m ³ /s	23		
Mass flow rate (wet basis), kg/h	110000		

Odour	Sampling time	Average		Test 1 1320 - 1322		Test 2 1325 - 1327	
		Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min
Lower uncertainty limit		4200		3200		4500	
Upper uncertainty limit		6500		5900		8300	
Analysis date & time				17/08/23, 1000 - 1245		17/08/23, 1000 - 1245	
Holding time				21 hours		21 hours	
Dilution factor				5		5	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		58					
Laboratory temp (°C)		22					
Last calibration date		October 2022					

3 Sample Plane Compliance

3.1 EPA 1 – Main Stack 1

Sampling Plane Details	
Sampling plane dimensions	2660 mm
Sampling plane area	5.56 m ²
Sampling port size, number	4" Flange (x4)
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 5 D
Upstream disturbance	Junction 20 D
No. traverses & points sampled	2 12
Sample plane conformance to USEPA Method :	Conforming

3.2 EPA 22 – Main Stack 2

Sampling Plane Details	
Source tested	Boiler
Pollution control equipment	Electrostatic precipitator - dry
Sampling plane dimensions	2450 mm
Sampling plane area	4.71 m ²
Sampling port size, number	4" Flange (x4)
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 10 D
Upstream disturbance	Junction 5 D
No. traverses & points sampled	2 20
Sample plane conformance to USEPA Method :	Conforming

3.3 Vacuum Pump 3 – (790 Couch)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	1006 mm
Sampling plane area	0.795 m ²
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
The number of traverses sampled is less than the requirement	
The number of points sampled is less than the requirement	
The gas temperature of the sampling plane is below the dew point	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The downstream disturbance is <1D from the sampling plane	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	

3.4 Vacuum Pump 7 – (794 First Bottom)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	906 mm
Sampling plane area	0.645 m ²
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
The number of traverses sampled is less than the requirement	
The number of points sampled is less than the requirement	
The gas temperature of the sampling plane is below the dew point	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The downstream disturbance is <1D from the sampling plane	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	

3.5 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	1500 x 1750 mm
Sampling plane area	2.63 m ²
Sampling port size, number	1/4 inch hole
Duct orientation & shape	Vertical Rectangular
Downstream disturbance	Exit 2 D
Upstream disturbance	Junction 0.1 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
The number of traverses sampled is less than the requirement	
The number of points sampled is less than the requirement	
The discharge is assumed to be composed of dry air and moisture	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	
The sampling plane is too near to the downstream disturbance but is greater than or equal to 1D	

3.6 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	2450 x 3500 mm
Sampling plane area	8.58 m ²
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical Rectangular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming

Comments

The number of traverses sampled is less than the requirement
The number of points sampled is less than the requirement
The gas temperature of the sampling plane is below the dew point

The sampling plane is deemed to be non-conforming due to the following reasons:

The downstream disturbance is <1D from the sampling plane
The upstream disturbance is <2D from the sampling plane
The stack or duct does not have the required number of access holes (ports)

4 Plant Operating Conditions

See Visy Pulp and Paper records for complete process conditions.

From information received from the site operator, unless otherwise noted it is our understanding that samples were collected during normal plant operations. Unless otherwise noted all samples were collected in compliance with Ektimo's QA/QC standards.

5 Test Methods

All sampling and analysis was performed by Ektimo unless otherwise specified. Specific details of the methods are available upon request.

Parameter	Sampling method	Analysis method	Uncertainty*	NATA accredited	
				Sampling	Analysis
Sampling points - Selection	NSW EPA TM-1 (AS 4323.1)	NA	NA	✓	NA
Flow rate, temperature & velocity	NSW EPA TM-2 (USEPA Method 2)	NSW EPA TM-2 (USEPA Method 2)	8%, 2%, 7%	NA	✓
Moisture content	NSW EPA TM-22 (USEPA Alt-Method 008)	NSW EPA TM-22 (USEPA Alt-Method 008)	19%	✓	✓
Odour	NSW EPA OM-7 (AS 4323.3)	NSW EPA OM-7 (AS 4323.3)	refer to results	✓	✓ [‡]
Odour from diffuse sources	NSW EPA OM-8 (AS 4323.4)	NSW EPA OM-8 (AS 4323.4)	refer to results	✓	✓ [‡]

180823

* Uncertainties cited in this table are estimated using typical values and are calculated at the 95% confidence level (coverage factor = 2).

‡ Odour analysis conducted at the Ektimo NSW EPA laboratory by forced choice olfactometry. Results were reported to Ektimo on 17 August 2023 in report ON-00213.

6 Quality Assurance/Quality Control Information

Ektimo is accredited by the National Association of Testing Authorities (NATA) for the sampling and analysis of air pollutants from industrial sources. Unless otherwise stated test methods used are accredited with the National Association of Testing Authorities. For full details, search for Ektimo at NATA's website www.nata.com.au.

Ektimo is accredited by NATA to ISO/IEC 17025 - Testing. ISO/IEC 17025 - Testing requires that a laboratory have adequate equipment to perform the testing, as well as laboratory personnel with the competence to perform the testing. This quality assurance system is administered and maintained by the Quality Director.

NATA is a member of APAC (Asia Pacific Accreditation Co-operation) and of ILAC (International Laboratory Accreditation Co-operation). Through mutual recognition arrangements with these organisations, NATA accreditation is recognised worldwide.

7 Definitions

The following symbols and abbreviations may be used in this test report:

% v/v	Volume to volume ratio
~	Approximately
<	Less than
>	Greater than
≥	Greater than or equal to
APHA	American Public Health Association, Standard Methods for the Examination of Water and Waste Water
AS	Australian Standard
BaP-TEQ	Benzo(a)pyrene toxic equivalents
BSP	British standard pipe
CEM/CEMS	Continuous emission monitoring/Continuous emission monitoring system
CTM	Conditional test method
D	Duct diameter or equivalent duct diameter for rectangular ducts
D ₅₀	'Cut size' of a cyclone is defined as the particle diameter at which the cyclone achieves a 50% collection efficiency i.e. half of the particles are retained by the cyclone and half pass through it. The D ₅₀ method simplifies the capture efficiency distribution by assuming that a given cyclone stage captures all of the particles with a diameter equal to or greater than the D ₅₀ of that cyclone and less than the D ₅₀ of the preceding cyclone.
DECC	Department of Environment & Climate Change (NSW)
Disturbance	A flow obstruction or instability in the direction of the flow which may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
DWER	Department of Water and Environmental Regulation (WA)
DEHP	Department of Environment and Heritage Protection (QLD)
EPA	Environment Protection Authority
FTIR	Fourier transform infra-red
ISC	Intersociety Committee, Methods of Air Sampling and Analysis
ISO	International Organisation for Standardisation
ITE	Individual threshold estimate
I-TEQ	International toxic equivalents
Lower bound	When an analyte is not present above the detection limit, the result is assumed to be equal to zero.
Medium bound	When an analyte is not present above the detection limit, the result is assumed to be equal to half of the detection limit.
NA	Not applicable
NATA	National Association of Testing Authorities
NIOSH	National Institute of Occupational Safety and Health
NT	Not tested or results not required
OM	Other approved method
OU	Odour unit. One OU is that concentration of odourant(s) at standard conditions that elicits a physiological response from a panel equivalent to that elicited by one Reference Odour Mass (ROM), evaporated in one cubic metre of neutral gas at standard conditions.
PM ₁₀	Particulate matter having an equivalent aerodynamic diameter less than or equal to 10 microns (µm).
PM _{2.5}	Particulate matter having an equivalent aerodynamic diameter less than or equal to 2.5 microns (µm).
PSA	Particle size analysis. PSA provides a distribution of geometric diameters, for a given sample, determined using laser diffraction.
RATA	Relative accuracy test audit
Semi-quantified VOCs	Unknown VOCs (those for which an analytical standard is not available), are identified by matching the mass spectrum of the chromatographic peak to the NIST Standard Reference Database (version 14.0), with a match quality exceeding 70%. An estimated concentration is determined by matching the area of the peak with the nearest suitable compound in the analytical calibration standard mixture.
STP	Standard temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0 °C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa.
TM	Test method
TOC	Total organic carbon. This is the sum of all compounds of carbon which contain at least one carbon-to-carbon bond, plus methane and its derivatives.
USEPA	United States Environmental Protection Agency
VDI	Verein Deutscher Ingenieure (Association of German Engineers)
Velocity difference	The percentage difference between the average of initial flows and after flows.
Vic EPA	Victorian Environment Protection Authority
VOC	Volatile organic compound. A carbon-based chemical compound with a vapour pressure of at least 0.010 kPa at 25°C or having a corresponding volatility under the given conditions of use. VOCs may contain oxygen, nitrogen and other elements. VOCs do not include carbon monoxide, carbon dioxide, carbonic acid, metallic carbides and carbonate salts.
WHO05-TEQ	World Health Organisation toxic equivalents
XRD	X-ray diffractometry
Upper bound	When an analyte is not present above the detection limit, the result is assumed to be equal to the detection limit.
95% confidence interval	Range of values that contains the true result with 95% certainty. This means there is a 5% risk that the true result is outside this range.

8 Appendices


Appendix A: Site Images



EPA 1 - Main Stack 1



EPA 22 – Main Stack 2



Cooling Pond 3A



Cooling Pond 3B



Vacuum Pump 3 – (790 Couch)



Vacuum Pump 7 – (794 First Bottom)



Vacuum Pump 9 (Paper Machine Hood Vent Exhaust)



Vacuum Pump 10 (Paper Machine Hood Vent Exhaust)

Ektimo

ektimo.com.au

1300 364 005

MELBOURNE (Head Office)

26 Redland Drive

Mitcham

VIC 3132

AUSTRALIA

SYDNEY

6/78 Reserve Road

Artarmon

NSW 2064

AUSTRALIA

WOLLONGONG

1/251 Princes Highway

Unanderra

NSW 2526

AUSTRALIA

PERTH

52 Cooper Road

Cockburn Central

WA 6164

AUSTRALIA

BRISBANE

3/109 Riverside Place

Morningside

QLD 4170

AUSTRALIA

Ektimo

Visy Pulp and Paper, Tumut

Emission Testing Report – Quarter 3 Testing (Odour)

Report R016507-1

ektimo.com.au



Accredited for compliance with ISO/IEC 17025 - Testing.
NATA is a signatory to the ILAC Mutual Recognition
Arrangement for the mutual recognition of the
equivalence of testing, calibration, and inspection reports.

Document Information

Client Name: Visy Pulp and Paper
Report Number: R016507-1
Date of Issue: 25 March 2024
Attention: Matthew O'Donovan
Address: 1302 Snowy Mountains Highway
Tumut NSW 2720
Testing Laboratory: Ektimo Pty Ltd, ABN 86 600 381 413

Report Authorisation

Aaron Davis
Operations Manager



NATA Accredited Laboratory
No. 14601

This document is confidential and is prepared for the exclusive use of Visy Pulp and Paper and those granted permission by Visy Pulp and Paper. The report shall not be reproduced except in full.

Please note that only numerical results pertaining to measurements conducted directly by Ektimo are covered by Ektimo terms of NATA accreditation as described in the Test Methods table. This does not include calculations that use data supplied by third-parties, comments, conclusions, or recommendations based upon the results. Refer to Test Methods section for full details of testing covered by NATA accreditation.

Table of Contents

- 1 Executive Summary4
- 1.1 Background4
- 1.2 Project Objective & Overview4
- 2 Results5
- 2.1 EPA 1 – Main Stack 15
- 2.2 EPA 22 – Main Stack 26
- 2.3 Cooling Pond 3A7
- 2.4 Cooling Pond 3B8
- 2.5 Cooling Tower 1 (#1 Paper Machine Side)9
- 2.6 Cooling Tower 2 (#2 Paper Machine Side)9
- 2.7 Vacuum Pump 3 – (790 Couch)10
- 2.8 Vacuum Pump 7 – (794 First Bottom)11
- 2.9 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)12
- 2.10 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)13
- 3 Sample Plane Compliance14
- 3.1 EPA 1 – Main Stack 114
- 3.2 EPA 22 – Main Stack 214
- 3.3 Cooling Tower 1 (#1 Paper Machine Side)14
- 3.4 Cooling Tower 2 (#2 Paper Machine Side)15
- 3.5 Vacuum Pump 3 – (790 Couch)15
- 3.6 Vacuum Pump 7 – (794 First Bottom)16
- 3.7 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)16
- 3.8 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)17
- 4 Plant Operating Conditions17
- 5 Test Methods18
- 6 Quality Assurance/Quality Control Information18
- 7 Definitions19
- Appendix A: Site Images20

1 Executive Summary

1.1 Background

Ektimo was engaged by Visy Pulp and Paper to perform an odour monitoring survey at their Tumut facility. The program incorporated both point source and area source (flux hood) monitoring.

1.2 Project Objective & Overview

The objective of the project was to conduct a monitoring program to quantify emissions from multiple discharge points.

Monitoring was performed as follows:

Location	Test Date	Test Parameters*
EPA 1 – Main Stack 1	22 February 2024	Odour (duplicate)
EPA 22 – Main Stack 2		
Cooling Pond 3A		Odour (single)
Cooling Pond 3B		
Cooling Tower 1 (#1 Paper Machine Side)		
Cooling Tower 2 (#2 Paper Machine Side)		
Vacuum Pump 3 – (790 Couch)		Odour (duplicate)
Vacuum Pump 7 – (794 First Bottom)		
Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)		
Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)		

* Flow rate, velocity, temperature, and moisture were also determined.

All results are reported on a dry basis at STP (except odour wet – STP).

2 Results

2.1 EPA 1 – Main Stack 1

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	EPA 1 - Main Stack 1
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		240226

Stack Parameters		
Moisture content, %v/v	21	
Gas molecular weight, g/g mole	28.0 (wet)	30.6 (dry)
Gas density at STP, kg/m ³	1.25 (wet)	1.36 (dry)
Gas density at discharge conditions, kg/m ³	0.69	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	0835	
Temperature, °C	194	
Temperature, K	467	
Velocity at sampling plane, m/s	28	
Volumetric flow rate, actual, m ³ /s	160	
Volumetric flow rate (wet STP), m ³ /s	86	
Volumetric flow rate (dry STP), m ³ /s	68	
Mass flow rate (wet basis), kg/h	390000	

Odour	Sampling time	Average		Test 1 0840 - 0850		Test 2 0855 - 0900	
		Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min
Results		1700	8600000	1600	8200000	1700	9000000
Lower uncertainty limit		1400		1200		1300	
Upper uncertainty limit		2000		2100		2300	
Analysis date & time				23/02/24, 1100-1345		23/02/24, 1100-1345	
Holding time				26 hours		26 hours	
Dilution factor				1		1	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		56					
Laboratory temp (°C)		21					
Last calibration date		October 2023					

2.2 EPA 22 – Main Stack 2

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	EPA 22 - Main Stack 2
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		

240226

Stack Parameters		
Moisture content, %v/v	21	
Gas molecular weight, g/g mole	28.0 (wet)	30.7 (dry)
Gas density at STP, kg/m ³	1.25 (wet)	1.37 (dry)
Gas density at discharge conditions, kg/m ³	0.72	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	0930	
Temperature, °C	174	
Temperature, K	447	
Velocity at sampling plane, m/s	23	
Volumetric flow rate, actual, m ³ /s	110	
Volumetric flow rate (wet STP), m ³ /s	62	
Volumetric flow rate (dry STP), m ³ /s	49	
Mass flow rate (wet basis), kg/h	280000	

Odour	Sampling time	Average		Test 1 0935 - 0945		Test 2 0950 - 0955	
		Odourant Flow		Odourant Flow		Odourant Flow	
		Concentration ou	Rate ou.m ³ /min	Concentration ou	Rate ou.m ³ /min	Concentration ou	Rate ou.m ³ /min
Results		1200	4400000	1200	4600000	1100	4200000
Lower uncertainty limit		960		920		850	
Upper uncertainty limit		1400		1600		1500	
Analysis date & time				23/02/24, 1100-1345		23/02/24, 1100-1345	
Holding time				26 hours		25 hours	
Dilution factor				1		1	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		56					
Laboratory temp (°C)		21					
Last calibration date		October 2023					

2.3 Cooling Pond 3A

Client	Visy Pulp and Paper	Test Location	Cooling Pond 3A
Date	22/02/2024	Plant/Site	Tumut
Report No.	R016507-1		Tumut, NSW
Ektimo Staff	Aaron Davis / Scott Woods		220907
Test Location Details			
Location Description	Green, brown murky liquid, not filling		
Surface Description	Clear surface, not aerating		
Area Classification	Industrial		
Source dimensions (L x W), m	50 x 32		
Source area, m ²	1600		
Sampling Method	AS4323.4 (Flux)		
Odour			
Sampling time, hrs	0850 - 0900		
Sample dilution	1		
Concentration, ou	120		
95% Confidence Interval	93 - 160		
Flux Emission Rate, ou.m³/m²/min	4.1		
Total area source emission rate, ou.m³/min	6500		
Flux Testing Parameters			
Equilibration time, hrs	0825 - 0849		
Sweep Rate @ STP, L/min	4.19		
Penetration Depth, mm	5		
Static Pressure, Pa	10		
Surface temperature, °C	21		
Chamber temperature, °C	25		
Ambient temperature, °C	22		

2.4 Cooling Pond 3B

Client	Visy Pulp and Paper	Test Location	Cooling Pond 3B
Date	22/02/2024	Plant/Site	Tumut
Report No.	R016507-1		Tumut, NSW
Ektimo Staff	Aaron Davis / Scott Woods		220907
Test Location Details			
Location Description	Brown, green murky liquid, filling up		
Surface Description	White foam and green sludge		
Area Classification	Industrial		
Source dimensions (L x W), m	50 x 32		
Source area, m ²	1600		
Sampling Method	AS4323.4 (Flux)		
Odour			
Sampling time, hrs	Test 1 0930 - 0940		
Sample dilution	1		
Concentration, ou	180		
Average concentration, ou	180		
95% Confidence Interval	130 - 230		
Flux Emission Rate, ou.m³/m²/min	5.9		
Total area source emission rate, ou.m³/min	9500		
Flux Testing Parameters			
Equilibration time, hrs	0905 - 0929		
Sweep Rate @ STP, L/min	4.26		
Penetration Depth, mm	5		
Static Pressure, Pa	15		
Surface temperature, °C	22		
Chamber temperature, °C	26		
Ambient temperature, °C	23		

2.5 Cooling Tower 1 (#1 Paper Machine Side)

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	Cooling Tower 1 (#1 Paper Machine Side)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		

Comments
The discharge is assumed to be composed of dry air and moisture

Odour	Sampling time	Results
		1020 - 1030
		Concentration
		ou
Results		160
Lower uncertainty limit		120
Upper uncertainty limit		220
Analysis date & time		23/02/24, 100-1345
Holding time		25 hours
Dilution factor		1
Bag material		Nalophan
Butanol threshold (ppb)		55.7
Laboratory temp (°C)		21
Last calibration date		October 2023

2.6 Cooling Tower 2 (#2 Paper Machine Side)

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	Cooling Tower 2 (#2 Paper Machine Side)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		

Comments
The discharge is assumed to be composed of dry air and moisture

Odour	Sampling time	Results
		1032 - 1042
		Concentration
		ou
Results		190
Lower uncertainty limit		140
Upper uncertainty limit		260
Analysis date & time		23/02/24, 100-1345
Holding time		25 hours
Dilution factor		1
Bag material		Nalophan
Butanol threshold (ppb)		55.7
Laboratory temp (°C)		21
Last calibration date		October 2023

2.7 Vacuum Pump 3 – (790 Couch)

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	Vacuum Pump 3 (790 Couch)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		240226

Comments
 The discharge is assumed to be composed of dry air and moisture
 The gas temperature of the sampling plane is below the dew point

Stack Parameters		
Moisture content, %v/v	14 (saturated)	
Gas molecular weight, g/g mole	27.4 (wet)	29.0 (dry)
Gas density at STP, kg/m ³	1.22 (wet)	1.29 (dry)
Gas density at discharge conditions, kg/m ³	0.98	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	1245	
Temperature, °C	52	
Temperature, K	325	
Velocity at sampling plane, m/s	8.1	
Volumetric flow rate, actual, m ³ /s	6.4	
Volumetric flow rate (wet STP), m ³ /s	5.1	
Volumetric flow rate (dry STP), m ³ /s	4.4	
Mass flow rate (wet basis), kg/h	23000	

Odour	Sampling time	Average		Test 1 1250 - 1252		Test 2 1253 - 1255	
		Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min
Results		27000	8300000	22000	6900000	32000	9700000
Lower uncertainty limit		22000		17000		24000	
Upper uncertainty limit		33000		30000		42000	
Analysis date & time				23/02/24, 1100-1345		23/02/24, 1100-1345	
Holding time				22 hours		22 hours	
Dilution factor				5		5	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		56					
Laboratory temp (°C)		21					
Last calibration date		October 2023					

2.8 Vacuum Pump 7 – (794 First Bottom)

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	Vacuum Pump 7 (794 First Bottom)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		240226

Comments
The discharge is assumed to be composed of dry air and moisture
The gas temperature of the sampling plane is below the dew point

Stack Parameters		
Moisture content, %v/v	12 (saturated)	
Gas molecular weight, g/g mole	27.7 (wet)	29.0 (dry)
Gas density at STP, kg/m ³	1.24 (wet)	1.29 (dry)
Gas density at discharge conditions, kg/m ³	1.00	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	1305	
Temperature, °C	48	
Temperature, K	321	
Velocity at sampling plane, m/s	7	
Volumetric flow rate, actual, m ³ /s	4.5	
Volumetric flow rate (wet STP), m ³ /s	3.7	
Volumetric flow rate (dry STP), m ³ /s	3.2	
Mass flow rate (wet basis), kg/h	16000	

Odour	Sampling time	Average		Test 1 1308 - 1310		Test 2 1312 - 1314	
		Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min
Results		17000	3600000	16000	3500000	17000	3800000
Lower uncertainty limit		14000		12000		13000	
Upper uncertainty limit		20000		21000		23000	
Analysis date & time				23/02/24, 1100-1345		23/02/24, 1100-1345	
Holding time				22 hours		22 hours	
Dilution factor				5		5	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		56					
Laboratory temp (°C)		21					
Last calibration date		October 2023					

2.9 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	Vacuum Pump 9 (Paper Machine Hood Vent Exhaust)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		240226

Comments
The discharge is assumed to be composed of dry air and moisture
The gas temperature of the sampling plane is below the dew point

Stack Parameters		
Moisture content, %v/v	27 (saturated)	
Gas molecular weight, g/g mole	26.0 (wet)	29.0 (dry)
Gas density at STP, kg/m ³	1.16 (wet)	1.29 (dry)
Gas density at discharge conditions, kg/m ³	0.89	
Gas Flow Parameters		
Flow measurement time(s) (hhmm)	1238	
Temperature, °C	66	
Temperature, K	339	
Velocity at sampling plane, m/s	10	
Volumetric flow rate, actual, m ³ /s	27	
Volumetric flow rate (wet STP), m ³ /s	20	
Volumetric flow rate (dry STP), m ³ /s	15	
Mass flow rate (wet basis), kg/h	85000	

Odour	Sampling time	Average		Test 1 1240 - 1242		Test 2 1244 - 1246	
		Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min	Concentration ou	Odourant Flow Rate ou.m ³ /min
Results		2800	3500000	2000	2500000	3600	4400000
Lower uncertainty limit		2300		1500		2700	
Upper uncertainty limit		3400		2700		4800	
Analysis date & time				23/02/24, 1100-1345		23/02/24, 1100-1345	
Holding time				23 hours		23 hours	
Dilution factor				5		5	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		56					
Laboratory temp (°C)		21					
Last calibration date		October 2023					

2.10 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)

Date	22/02/2024	Client	Visy Pulp and Paper
Report	R016507-1	Stack ID	Vacuum Pump 10 (Paper Machine Hood Vent Exhaust)
Licence No.	10232	Location	Tumut
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Please refer to client records.		

240226

Comments
The discharge is assumed to be composed of dry air and moisture
The gas temperature of the sampling plane is below the dew point

Stack Parameters			
Moisture content, %v/v	8.1 (saturated)		
Gas molecular weight, g/g mole	28.1 (wet)	29.0 (dry)	
Gas density at STP, kg/m ³	1.25 (wet)	1.29 (dry)	
Gas density at discharge conditions, kg/m ³	1.04		
Gas Flow Parameters			
Flow measurement time(s) (hhmm)	1325		
Temperature, °C	41		
Temperature, K	314		
Velocity at sampling plane, m/s	3.3		
Volumetric flow rate, actual, m ³ /s	28		
Volumetric flow rate (wet STP), m ³ /s	23		
Volumetric flow rate (dry STP), m ³ /s	22		
Mass flow rate (wet basis), kg/h	110000		

Odour	Sampling time	Average		Test 1		Test 2	
		Odourant Flow		1328 - 1330		1332 - 1334	
		Concentration	Rate	Concentration	Rate	Concentration	Rate
		ou	ou.m ³ /min	ou	ou.m ³ /min	ou	ou.m ³ /min
Results		9400	13000000	9400	13000000	9400	13000000
Lower uncertainty limit		7700		7100		7100	
Upper uncertainty limit		12000		13000		13000	
Analysis date & time				23/02/24, 1100-1345		23/02/24, 1100-1345	
Holding time				22 hours		22 hours	
Dilution factor				5		5	
Bag material				Nalophan		Nalophan	
Butanol threshold (ppb)		56					
Laboratory temp (°C)		21					
Last calibration date		October 2023					

3 Sample Plane Compliance

3.1 EPA 1 – Main Stack 1

Sampling Plane Details	
Sampling plane dimensions	2660 mm
Sampling plane area	5.56 m ²
Sampling port size, number	4" Flange (x4)
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 5 D
Upstream disturbance	Junction 20 D
No. traverses & points sampled	2 12
Sample plane conformance to USEPA Method 1	Conforming

3.2 EPA 22 – Main Stack 2

Sampling Plane Details	
Source tested	Boiler
Pollution control equipment	Electrostatic precipitator - dry
Sampling plane dimensions	2450 mm
Sampling plane area	4.71 m ²
Sampling port size, number	4" Flange (x4)
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 10 D
Upstream disturbance	Junction 5 D
No. traverses & points sampled	2 20
Sample plane conformance to USEPA Method 1	Conforming

3.3 Cooling Tower 1 (#1 Paper Machine Side)

Sampling Plane Details	
Sampling plane dimensions	Exit diameter could not be measured mm
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
Velocity and volumetric flowrate measurements could not be taken.	
The number of traverses sampled is less than the requirement	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The downstream disturbance is <1D from the sampling plane	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	

3.4 Cooling Tower 2 (#2 Paper Machine Side)

Sampling Plane Details	
Sampling plane dimensions	Exit diameter could not be measured mm
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
Velocity and volumetric flowrate measurements could not be taken.	
The number of traverses sampled is less than the requirement	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The downstream disturbance is <1D from the sampling plane	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	

3.5 Vacuum Pump 3 – (790 Couch)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	1006 mm
Sampling plane area	0.795 m ²
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
The number of traverses sampled is less than the requirement	
The number of points sampled is less than the requirement	
The gas temperature of the sampling plane is below the dew point	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The downstream disturbance is <1D from the sampling plane	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	

3.6 Vacuum Pump 7 – (794 First Bottom)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	906 mm
Sampling plane area	0.645 m ²
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
The number of traverses sampled is less than the requirement	
The number of points sampled is less than the requirement	
The gas temperature of the sampling plane is below the dew point	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The downstream disturbance is <1D from the sampling plane	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	

3.7 Vacuum Pump 9 – (Paper Machine Hood Vent Exhaust)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	1500 x 1750 mm
Sampling plane area	2.63 m ²
Sampling port size, number	1/4 inch hole
Duct orientation & shape	Vertical Rectangular
Downstream disturbance	Exit 2 D
Upstream disturbance	Junction 0.1 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming
Comments	
The number of traverses sampled is less than the requirement	
The number of points sampled is less than the requirement	
The gas temperature of the sampling plane is below the dew point	
The sampling plane is deemed to be non-conforming due to the following reasons:	
The upstream disturbance is <2D from the sampling plane	
The stack or duct does not have the required number of access holes (ports)	
The sampling plane is too near to the downstream disturbance but is greater than or equal to 1D	

3.8 Vacuum Pump 10 – (Paper Machine Hood Vent Exhaust)

Sampling Plane Details	
Source tested	Vacuum pump outlet
Sampling plane dimensions	2450 x 3500 mm
Sampling plane area	8.58 m ²
Sampling port size, number	Sampled at exit
Duct orientation & shape	Vertical Rectangular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	1 1
Sample plane conformance to AS 4323.1	Non-conforming

Comments

The number of traverses sampled is less than the requirement
The number of points sampled is less than the requirement
The gas temperature of the sampling plane is below the dew point

The sampling plane is deemed to be non-conforming due to the following reasons:

The downstream disturbance is <1D from the sampling plane
The upstream disturbance is <2D from the sampling plane
The stack or duct does not have the required number of access holes (ports)

4 Plant Operating Conditions

See Visy Pulp and Paper records for complete process conditions.

Based on information received from Visy Pulp and Paper personnel, it is our understanding that samples were collected during typical plant operations.

5 Test Methods

All sampling and analysis was performed by Ektimo unless otherwise specified. Specific details of the methods are available upon request.

Parameter	Sampling method	Analysis method	Uncertainty*	NATA accredited	
				Sampling	Analysis
Sampling points - Selection	NSW EPA TM-1 (AS 4323.1)	NA	NA	✓	NA
Flow rate, temperature & velocity	NSW EPA TM-2 (USEPA Method 2)	NSW EPA TM-2 (USEPA Method 2)	8%, 2%, 7%	NA	✓
Moisture content	NSW EPA TM-22 (USEPA Alt-Method 008)	NSW EPA TM-22 (USEPA Alt-Method 008)	19%	✓	✓
Odour	NSW EPA OM-7 (AS 4323.3)	NSW EPA OM-7 (AS 4323.3)	refer to results	✓	✓ [‡]
Odour from diffuse sources	NSW EPA OM-8 (AS 4323.4)	NSW EPA OM-8 (AS 4323.4)	refer to results	✓	✓ [‡]

220224

* Uncertainties cited in this table are estimated using typical values and are calculated at the 95% confidence level (coverage factor = 2).

[‡] Odour analysis conducted at the Ektimo NSW laboratory by forced choice olfactometry. Results were reported to Ektimo on 23 February 2024 in report ON-00238.

6 Quality Assurance/Quality Control Information

Ektimo is accredited by the National Association of Testing Authorities (NATA) for the sampling and analysis of air pollutants from industrial sources. Unless otherwise stated test methods used are accredited with the National Association of Testing Authorities. For full details, search for Ektimo at NATA's website www.nata.com.au.

Ektimo is accredited by NATA to ISO/IEC 17025 - Testing. ISO/IEC 17025 - Testing requires that a laboratory have adequate equipment to perform the testing, as well as laboratory personnel with the competence to perform the testing. This quality assurance system is administered and maintained by the Quality Director.

NATA is a member of APAC (Asia Pacific Accreditation Co-operation) and of ILAC (International Laboratory Accreditation Co-operation). Through mutual recognition arrangements with these organisations, NATA accreditation is recognised worldwide.

Unless specifically noted, all samples were collected and handled in accordance with Ektimo's QA/QC standards.

7 Definitions

The following symbols and abbreviations may be used in this test report:

% v/v	Volume to volume ratio
~	Approximately
<	Less than
>	Greater than
≥	Greater than or equal to
APHA	American Public Health Association, Standard Methods for the Examination of Water and Waste Water
AS	Australian Standard
BaP-TEQ	Benzo(a)pyrene toxic equivalents
BSP	British standard pipe
CEM/CEMS	Continuous emission monitoring/Continuous emission monitoring system
CTM	Conditional test method
D	Duct diameter or equivalent duct diameter for rectangular ducts
D ₅₀	'Cut size' of a cyclone is defined as the particle diameter at which the cyclone achieves a 50% collection efficiency i.e. half of the particles are retained by the cyclone and half pass through it. The D ₅₀ method simplifies the capture efficiency distribution by assuming that a given cyclone stage captures all of the particles with a diameter equal to or greater than the D ₅₀ of that cyclone and less than the D ₅₀ of the preceding cyclone.
DECC	Department of Environment & Climate Change (NSW)
Disturbance	A flow obstruction or instability in the direction of the flow which may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
DWER	Department of Water and Environmental Regulation (WA)
DEHP	Department of Environment and Heritage Protection (QLD)
EPA	Environment Protection Authority
FTIR	Fourier transform infra-red
ISC	Intersociety Committee, Methods of Air Sampling and Analysis
ISO	International Organisation for Standardisation
ITE	Individual threshold estimate
I-TEQ	International toxic equivalents
Lower bound	When an analyte is not present above the detection limit, the result is assumed to be equal to zero.
Medium bound	When an analyte is not present above the detection limit, the result is assumed to be equal to half of the detection limit.
NA	Not applicable
NATA	National Association of Testing Authorities
NIOSH	National Institute of Occupational Safety and Health
NT	Not tested or results not required
OM	Other approved method
OU	Odour unit. One OU is that concentration of odourant(s) at standard conditions that elicits a physiological response from a panel equivalent to that elicited by one Reference Odour Mass (ROM), evaporated in one cubic metre of neutral gas at standard conditions.
PM ₁₀	Particulate matter having an equivalent aerodynamic diameter less than or equal to 10 microns (µm).
PM _{2.5}	Particulate matter having an equivalent aerodynamic diameter less than or equal to 2.5 microns (µm).
PSA	Particle size analysis. PSA provides a distribution of geometric diameters, for a given sample, determined using laser diffraction.
RATA	Relative accuracy test audit
Semi-quantified VOCs	Unknown VOCs (those for which an analytical standard is not available), are identified by matching the mass spectrum of the chromatographic peak to the NIST Standard Reference Database (version 14.0), with a match quality exceeding 70%. An estimated concentration is determined by matching the area of the peak with the nearest suitable compound in the analytical calibration standard mixture.
STP	Standard temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0 °C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa.
TM	Test method
TOC	Total organic carbon. This is the sum of all compounds of carbon which contain at least one carbon-to-carbon bond, plus methane and its derivatives.
USEPA	United States Environmental Protection Agency
VDI	Verein Deutscher Ingenieure (Association of German Engineers)
Velocity difference	The percentage difference between the average of initial flows and after flows.
Vic EPA	Victorian Environment Protection Authority
VOC	Volatile organic compound. A carbon-based chemical compound with a vapour pressure of at least 0.010 kPa at 25°C or having a corresponding volatility under the given conditions of use. VOCs may contain oxygen, nitrogen and other elements. VOCs do not include carbon monoxide, carbon dioxide, carbonic acid, metallic carbides and carbonate salts.
WHO05-TEQ	World Health Organisation toxic equivalents
XRD	X-ray diffractometry
Upper bound	When an analyte is not present above the detection limit, the result is assumed to be equal to the detection limit.
95% confidence interval	Range of values that contains the true result with 95% certainty. This means there is a 5% risk that the true result is outside this range.

Appendix A: Site Images



EPA 1 - Main Stack 1



EPA 22 - Main Stack 2



Cooling Pond 3A



Cooling Pond 3B



Vacuum Pump 3 - (790 Couch)



Vacuum Pump 7 - (794 First Bottom)



Vacuum Pump 9 (Paper Machine Hood Vent Exhaust)



Vacuum Pump 10 (Paper Machine Hood Vent Exhaust)



Cooling Tower (#1 Paper Machine Side)



Cooling Tower (#2 Paper Machine Side)

Ektimo

ektimo.com.au

1300 364 005

MELBOURNE (Head Office)

26 Redland Drive

Mitcham

VIC 3132

AUSTRALIA

SYDNEY

6/78 Reserve Road

Artarmon

NSW 2064

AUSTRALIA

WOLLONGONG

1/251 Princes Highway

Unanderra

NSW 2526

AUSTRALIA

PERTH

52 Cooper Road

Cockburn Central

WA 6164

AUSTRALIA

BRISBANE

3/109 Riverside Place

Morningside

QLD 4170

AUSTRALIA