



Visy Pulp and Paper Tumut CEMS - Correction Log

13/12/2024

Reporting Period: 1/11/2024 - 1/12/2024

Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity					
Period: 6 Minutes		Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/11/24 08:12	01/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.15
02/11/24 08:12	02/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.56
03/11/24 08:12	03/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.93
04/11/24 08:12	04/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.94
05/11/24 08:12	05/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.13
06/11/24 08:12	06/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.46
07/11/24 08:12	07/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.76
08/11/24 08:12	08/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.05
09/11/24 08:12	09/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.38
10/11/24 08:12	10/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.11
11/11/24 08:12	11/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.27
12/11/24 08:12	12/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.28
13/11/24 08:12	13/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.81
14/11/24 08:12	14/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.91
15/11/24 08:12	15/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.64
16/11/24 08:12	16/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.74
17/11/24 08:12	17/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.29
18/11/24 08:12	18/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.85

19/11/24 08:12	19/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.35
20/11/24 08:12	20/11/24 08:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.45
26/11/24 08:06	26/11/24 08:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.54
27/11/24 08:06	27/11/24 08:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.07
28/11/24 08:06	28/11/24 08:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.81
29/11/24 08:06	29/11/24 08:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.33
30/11/24 08:06	30/11/24 08:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.94

Power Boiler

Monitoring Location No: 3
Monitoring Type: Continuous
Sample Type: Air
Description: Discharge duct downstream of Power Boiler prior to junction with Stack 1

Carbon Monoxide (CO)		Period: 60 Minutes	Limit: 140.00 mg/Nm ³		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
27/11/24 08:00	27/11/24 09:00	Instrument Error	Normal (Steady State)	Group Instrumentation doing maintenance on Procal Unit.	154.29

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

