



FOR A BETTER WORLD

126 Andrews Road,
Penrith NSW 2750
Australia
T 13 8479

Water Monitoring Data Report

The table summarises the results of testing carried out on the water ponds for the 2023/24 reporting period.

Site: Visy Recycling (PH Penrith Operations Pty Ltd), Penrith NSW

Licence No: 20381

Tester: ALS Environmental Sydney

Report Nos:	Report dates:	Test dates
ES2404624	08/07/2024	13/02/2024
ES2414265	10/05/2024	02/05/2024
ES2422318	16/07/2024	05/07/2024
ES2428474	05/09/2024	30/08/2024

Table: Summary of Average Emission Test Results

Pollutant	Unit of measure	Concentration limit	Pond 1 Results	Pond 2 Result	Compliance
Ammonia	Milligrams per litre	1	0.02	0.01	Yes
BOD	Milligrams per litre	10	5	5	Yes
pH	pH	6.5<>8.5	7.44	7.33	Yes
Total suspended solids	Milligrams per litre	50	9	35.50	Yes

All results comply with the Environmental Protection Licence emission limits.

Verified by:

Terry Cotter
Visy NSW HSE Manager

Date: 20/12/2024