

Visy Pulp and Paper Tumut CEMS - Correction Log

Reporting Period: 1/03/2021 - 1/04/2021 Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Flow		Period: 60 Minutes	Limit: 100.00 Nm ³ /s		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
09/03/21 09:00	09/03/21 10:00	Instrument Error	Normal (Steady State)	Maintenance service on Procal	107.50

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/03/21 14:36	01/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.65
02/03/21 14:36	02/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.72
03/03/21 14:36	03/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.93
04/03/21 14:36	04/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.96
05/03/21 14:36	05/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.15
06/03/21 14:36	06/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.06
07/03/21 14:36	07/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.18
08/03/21 14:36	08/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	31.44
09/03/21 14:36	09/03/21 14:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.12
16/03/21 11:30	16/03/21 11:36	Instrument Error	Normal (Steady State)	Opacity was calibrated by maintenance team.	21.43
16/03/21 14:30	16/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.76
17/03/21 14:30	17/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.17
18/03/21 14:30	18/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.80
19/03/21 14:30	19/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.14
20/03/21 14:30	20/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.52

21/03/21 14:30	21/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.54
22/03/21 14:30	22/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.90
23/03/21 14:30	23/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.67
24/03/21 14:30	24/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.42
25/03/21 14:30	25/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.65
26/03/21 14:30	26/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.77
27/03/21 14:30	27/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.43
28/03/21 14:30	28/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.28
29/03/21 14:30	29/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.00
30/03/21 14:30	30/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.81
31/03/21 14:30	31/03/21 14:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.91

Sulphur Dioxide (SO2) Period: 60 Minutes Limit: 250.00 mg/Nm3					
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
10/03/21 22:00	11/03/21 00:00	Instrument Error	Normal (Steady State)	Changed stack A Procal analyzer out.	311.07

Power Boiler

Monitoring Location No: 3
Monitoring Type: Continuous
Sample Type: Air
Description: Discharge duct downstream of Power Boiler prior to junction with Stack 1

Carbon Monoxide (CO) Period: 60 Minutes Limit: 140.00 mg/Nm3					
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
10/03/21 15:00	10/03/21 16:00	Instrument Error	Normal (Steady State)	Changed out CO Power boiler CO analyzer	173.07

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager


