

Reporting Period:

1/01/2021 - 1/02/2021

Environment Protection Licence No:

10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation		Max Reading
02/01/21 14:48	02/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		20.41
03/01/21 14:48	03/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.04
04/01/21 14:48	04/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.22
05/01/21 14:48	05/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.67
06/01/21 14:48	06/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.32
07/01/21 14:48	07/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.41
08/01/21 14:48	08/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.32
09/01/21 14:48	09/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.62
10/01/21 14:48	10/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.92
11/01/21 14:48	11/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		22.11
12/01/21 14:48	12/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		22.49
13/01/21 14:48	13/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		37.10
14/01/21 14:48	14/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		22.49
15/01/21 14:48	15/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		22.03
16/01/21 14:48	16/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		23.57
17/01/21 14:48	17/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		23.83
18/01/21 14:48	18/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		22.59
19/01/21 14:48	19/01/21 14:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		22.86
26/01/21 14:42	26/01/21 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		20.86
27/01/21 14:42	27/01/21 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration		21.07

28/01/21 14:42	28/01/21 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.19
29/01/21 14:42	29/01/21 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.11
30/01/21 14:42	30/01/21 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.29
31/01/21 14:42	31/01/21 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.71

Main Stack 2

Monitoring Location No: 22
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 2 to atmosphere

Opacity					
Period: 6 Minutes		Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
18/01/21 10:48	18/01/21 10:54	Instrument Error	Normal (Steady State)	Maintenance done on CEMS unit.	26.30
18/01/21 11:24	18/01/21 11:30	Instrument Error	Normal (Steady State)	Maintenance done on CEMS unit.	30.90
18/01/21 11:36	18/01/21 11:42	Instrument Error	Normal (Steady State)	Maintenance done on CEMS unit.	46.99

TRS (as H2S)					
Period: 60 Minutes		Limit: 3.60 mg/Nm3			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
03/01/21 02:00	03/01/21 03:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	3.89
10/01/21 02:00	10/01/21 03:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	3.88
17/01/21 02:00	17/01/21 03:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	4.05
24/01/21 02:00	24/01/21 03:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	4.21

Authorised By:

(J. Oliver)

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

