

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading	
01/02/23 16:42	01/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.91	
02/02/23 16:42	02/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.75	
03/02/23 16:42	03/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.03	
04/02/23 16:42	04/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.06	
05/02/23 16:42	05/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.35	
06/02/23 16:42	06/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.59	
07/02/23 16:42	07/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.34	
08/02/23 16:42	08/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.15	
09/02/23 16:42	09/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.32	
10/02/23 16:42	10/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.52	
11/02/23 16:42	11/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.78	
12/02/23 16:42	12/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.03	
13/02/23 16:42	13/02/23 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.68	
19/02/23 16:36	19/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.41	
20/02/23 16:36	20/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.79	
21/02/23 16:36	21/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.29	
22/02/23 16:36	22/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.55	
23/02/23 16:36	23/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.70	

24/02/23 16:36	24/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.90
25/02/23 16:36	25/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.36
26/02/23 16:36	26/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.33
27/02/23 16:36	27/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.22
28/02/23 16:36	28/02/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.15

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

