

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/11/22 17:06	01/11/22 17:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.09
02/11/22 17:06	02/11/22 17:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.53
03/11/22 17:06	03/11/22 17:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.82
04/11/22 17:06	04/11/22 17:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.51
05/11/22 17:06	05/11/22 17:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.36
06/11/22 17:06	06/11/22 17:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.89
07/11/22 17:06	07/11/22 17:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.30
13/11/22 17:00	13/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.32
14/11/22 17:00	14/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.60
15/11/22 17:00	15/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.97
16/11/22 17:00	16/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.21
17/11/22 17:00	17/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.34
18/11/22 17:00	18/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.30
19/11/22 17:00	19/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.05
20/11/22 17:00	20/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.79
21/11/22 17:00	21/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.33
22/11/22 17:00	22/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.09
23/11/22 17:00	23/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.82

24/11/22 17:00	24/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.18
25/11/22 17:00	25/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.20
26/11/22 17:00	26/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.97
27/11/22 17:00	27/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.00
28/11/22 17:00	28/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.30
29/11/22 17:00	29/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.07
30/11/22 17:00	30/11/22 17:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.59

Main Stack 2


Monitoring Location No: 22
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 2 to atmosphere

Hydrogen Chloride (HCl)		Period: 60 Minutes	Limit: 50.00 mg/Nm3		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
04/11/22 12:00	04/11/22 13:00	Instrument Error	Normal (Steady State)	Weekly Maintenance Calibration	55.00
06/11/22 03:00	06/11/22 04:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	57.96

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
14/11/22 01:00	14/11/22 01:06	Instrument Error	Normal (Steady State)	Opacity instrument impacted by heavy rain indicating an exceedance.	27.67

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

