



Visy Pulp and Paper Tumut CEMS - Correction Log

9/06/2022

Reporting Period: 1/05/2022 - 1/06/2022

Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Flow					
Period: 60 Minutes		Limit: 100.00 Nm3/s			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
19/05/22 10:00	19/05/22 13:00	Instrument Error	Normal (Steady State)	Stack quality testing on the day by EKTIMO	143.72

Opacity					
Period: 6 Minutes		Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
06/05/22 16:48	06/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.58
07/05/22 16:48	07/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.35
08/05/22 16:48	08/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.98
09/05/22 16:48	09/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.30
10/05/22 16:48	10/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.87
11/05/22 16:48	11/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.99
13/05/22 16:48	13/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.82
14/05/22 16:48	14/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.85
15/05/22 16:48	15/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.75
16/05/22 16:48	16/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.45
17/05/22 16:48	17/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.90
18/05/22 14:42	18/05/22 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	38.72
18/05/22 16:18	18/05/22 16:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.54

18/05/22 16:48	18/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	27.41
19/05/22 16:48	19/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.97
20/05/22 16:48	20/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.17
21/05/22 16:48	21/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.75
22/05/22 16:48	22/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.19
23/05/22 16:48	23/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.77
24/05/22 16:48	24/05/22 16:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.39
30/05/22 16:42	30/05/22 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.24
31/05/22 16:42	31/05/22 16:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.06

TRS (as H2S) Period: 60 Minutes Limit: 3.60 mg/Nm3					
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
26/05/22 09:00	26/05/22 15:00	Instrument Error	Normal (Steady State)	Maintenance worked on TRS	28.19

Authorised By:

Uday Bhagwat
Pulp Mill Manager

Johan Stoltz
General Manager


