

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere


Opacity						Period: 6 Minutes	Limit: 20.00 %
Start Time	End Time	Cause	Operational State	Explanation	Max Reading		
01/03/23 16:36	01/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.03		
02/03/23 16:36	02/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.38		
03/03/23 16:36	03/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.36		
04/03/23 16:36	04/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.56		
05/03/23 16:36	05/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.80		
06/03/23 16:36	06/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.32		
07/03/23 16:36	07/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.43		
08/03/23 16:36	08/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.29		
09/03/23 16:36	09/03/23 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.11		
15/03/23 16:30	15/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.31		
16/03/23 16:30	16/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.56		
17/03/23 16:30	17/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.53		
18/03/23 16:30	18/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.96		
19/03/23 16:30	19/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.29		
20/03/23 16:30	20/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.57		
21/03/23 16:30	21/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.94		
22/03/23 16:30	22/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.62		
23/03/23 16:30	23/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.11		

24/03/23 16:30	24/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.12
25/03/23 16:30	25/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.42
26/03/23 16:30	26/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.69
27/03/23 16:30	27/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.36
28/03/23 16:30	28/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.30
29/03/23 16:30	29/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.35
30/03/23 16:30	30/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	33.34
31/03/23 16:30	31/03/23 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.46

Authorised By:

Uday Bhagwat
Pulp Mill Manager

Johan Stoltz
General Manager



Suro Olivier
(acting)