

## Main Stack 1

Monitoring Location No: 1  
 Monitoring Type: Continuous  
 Sample Type: Air  
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading	
01/07/22 16:36	01/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.17	
02/07/22 16:36	02/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.60	
03/07/22 16:36	03/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.49	
04/07/22 10:18	04/07/22 10:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	27.21	
04/07/22 16:36	04/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.52	
05/07/22 16:36	05/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.33	
06/07/22 16:36	06/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.95	
07/07/22 16:36	07/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.18	
08/07/22 16:36	08/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.05	
09/07/22 16:36	09/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.76	
10/07/22 16:36	10/07/22 16:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.41	
17/07/22 16:30	17/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.83	
18/07/22 16:30	18/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.02	
19/07/22 16:30	19/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.14	
20/07/22 16:30	20/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.70	
21/07/22 16:30	21/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.93	
22/07/22 16:30	22/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.78	
23/07/22 16:30	23/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.47	

24/07/22 16:30	24/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.92
25/07/22 16:30	25/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.91
26/07/22 16:30	26/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.51
27/07/22 16:30	27/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.08
28/07/22 16:30	28/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.09
29/07/22 16:30	29/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.94
30/07/22 16:30	30/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.56
31/07/22 16:30	31/07/22 16:36	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.14

## Main Stack 2

Monitoring Location No: 22  
Monitoring Type: Continuous  
Sample Type: Air  
Description: Exit point from Stack 2 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
05/07/22 13:24	05/07/22 13:42	Instrument Error	Normal (Steady State)	Monthly maintenance and calibration (E&I)	37.66
05/07/22 13:48	05/07/22 13:54	Instrument Error	Normal (Steady State)	Monthly maintenance and calibration (E&I)	44.93

Authorised By:

Uday Bhagwat  
Pulp Mill Manager

Johan Stoltz  
General Manager

  
\_\_\_\_\_  
Jaco Olivier

  
\_\_\_\_\_