



Visy Pulp and Paper Tumut CEMS - Exceedance Report

20/03/2023

Reporting Period: 1/02/2023 - 1/03/2023 Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 1 to atmosphere

Opacity						
Period: 6 Minutes		Limit: 20.00 %				
Start Time	End Time	Cause	Operational State	Explanation	Corrective Action	Max Reading
02/02/23 12:18	02/02/23 12:36	Lime Kiln B	Lime Kiln B Un Scheduled Start-up/Shut-down	Kiln feed stopped to shoot a ring.	Plant restarted and stabilized.	35.59
02/02/23 12:48	02/02/23 13:00	Lime Kiln B	Lime Kiln B Scheduled Start-up/Shut-down	Lime Kiln burner tripped out again after start up.	Kiln restarted and stabilized	27.65
09/02/23 16:24	09/02/23 16:30	Lime Kiln B	Lime Kiln A Un Scheduled Start-up/Shut-down	Kiln tripped due to lime feed screw tripping	Plant restarted and stabilized	20.04
24/02/23 10:48	24/02/23 11:06	Lime Kiln B	Lime Kiln B Un Scheduled Start-up/Shut-down	Kiln B Burner tripped.	Burner restarted and plant stabilized.	33.16

Main Stack 2

Monitoring Location No: 22
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 2 to atmosphere

Opacity						
Period: 6 Minutes		Limit: 20.00 %				

Start Time	End Time	Cause	Operational State	Explanation	Corrective Action	Max Reading
01/02/23 15:42	01/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	22.25
02/02/23 15:42	02/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	20.99
03/02/23 15:42	03/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	20.54
04/02/23 15:42	04/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.69
05/02/23 15:42	05/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	22.76
06/02/23 15:42	06/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.26
07/02/23 15:42	07/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	21.96
08/02/23 15:42	08/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	22.38
09/02/23 15:42	09/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	23.84
10/02/23 15:42	10/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	23.38
11/02/23 15:42	11/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	25.26
12/02/23 15:42	12/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	26.17
13/02/23 15:42	13/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Caloibration	n/a	25.11
14/02/23 15:42	14/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Caloibration	n/a	25.85
15/02/23 15:42	15/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	25.84
16/02/23 15:42	16/02/23 15:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	23.82
21/02/23 15:36	21/02/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	21.46
23/02/23 15:36	23/02/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	21.64
24/02/23 15:36	24/02/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.36
25/02/23 15:36	25/02/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	21.20
26/02/23 15:36	26/02/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.05
27/02/23 15:36	27/02/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.02
28/02/23 15:36	28/02/23 15:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	22.39

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

