



Visy Pulp and Paper Tumut CEMS - Exceedance Report

6/10/2021

Reporting Period: 1/09/2021 - 1/10/2021 Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity						
		Period: 6 Minutes	Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Corrective Action	Max Reading
02/09/21 16:06	02/09/21 16:30	Power Boiler EP	Normal (Steady State)	Tested load burners and started sootblowing at the same time excess air and steam increased velocity through boiler.	Completed load burner test and sootblowing, everything back to normal.	35.44
07/09/21 21:48	07/09/21 22:00	Recovery Boiler A ESP1	Normal (Steady State)	ESP Field 3 tripped - Sync Fail alarm came up.	Field 3 reset and started with no lingering issues	25.47
16/09/21 13:54	16/09/21 14:00	Lime Kiln B	Lime Kiln B Scheduled Start-up/Shut-down	Maintenance work carried out on Kiln, Exceedance caused by start up while purging the kiln.	Plant started and stabilised.	24.32

Main Stack 2

Monitoring Location No: 22
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 2 to atmosphere

Opacity						
		Period: 6 Minutes	Limit: 20.00 %			

Start Time	End Time	Cause	Operational State	Explanation	Corrective Action	Max Reading
01/09/21 22:12	01/09/21 22:18	Recovery Boiler B ESP1/ESP2	Normal (Steady State)	Auto calibration	None Required	26.10
02/09/21 22:12	02/09/21 22:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	23.54
03/09/21 22:12	03/09/21 22:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	21.54
07/09/21 22:06	07/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	20.98
08/09/21 22:06	08/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	22.07
09/09/21 22:06	09/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	20.58
10/09/21 22:06	10/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	22.55
11/09/21 22:06	11/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	22.43
12/09/21 22:06	12/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	23.06
13/09/21 22:06	13/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto calibration	None required	24.98
14/09/21 22:06	14/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	22.77
15/09/21 22:06	15/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	25.15
16/09/21 22:06	16/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	23.40
17/09/21 22:06	17/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	24.54
18/09/21 22:06	18/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	25.18
19/09/21 22:06	19/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None required	24.62
20/09/21 22:06	20/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	25.41
21/09/21 22:06	21/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	26.26
22/09/21 22:06	22/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	25.53
23/09/21 22:06	23/09/21 22:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	20.82
29/09/21 22:00	29/09/21 22:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	22.35
30/09/21 22:00	30/09/21 22:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	21.44

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

