

Modification Approval

Section 75W of the *Environmental Planning and Assessment Act 1979*

I, the Acting Executive Director, Major Project Assessments, as delegate for the Minister for Planning, modify the project approval referred to in Schedule 1, in the manner indicated in Schedule 2.



Yolande Stone
A / Executive Director
as Delegate for the Minister for Planning

Sydney

6 Aug 2007

File No: 9043050

SCHEDULE 1

- Project Approval:** Granted by the Minister for Planning on 1 May 2007.
- In respect of:** Project application 06_0159 made by Visy Pulp and Paper Pty Ltd, in relation to land described by Lots 5, 12, 14, 19, 42, 57, 61, 62, 63, 64, 76, 84, 91, 92, 93, 94, 103, 105, 106, 107, 115, 116, 117, 118, 119, 138 in DP No. 757228; Lots 211, 219, 220, 221, 222, 223, 224, 229, 230 and 235 in DP No. 757252; Lot 1 in DP No. 832090; Lot 4 in DP No. 1004478; Lot 1 in DP No. 1082770; Lots 102 and 103 in DP No. 1035564; Lot 7002 in DP No. 96829 and Lot 1 DP 27482; 436 Gadara Road, Tumut, Tumut local government area
- For the following:** Visy Pulp and Paper Tumut Mill expansion.
- Modification Application:** Modification (06_0159 Mod 1) of the project approval to change the total reduced sulphides emission limit for main stack 2 as a result of changes to the installation phasing of certain project components.
-

SCHEDULE 2

The project approval is modified by:

1. Replacing condition 1.1 with the following:
 - 1.1 The Proponent shall carry out the project generally in accordance with the:
 - a) Major Projects Application 06_0159;
 - b) *Visy Pulp and Paper Proposed Mill Expansion, Tumut NSW, Final Environmental Assessment*, prepared by Visy Pulp and Paper Pty Ltd and dated January 2007;
 - c) *Visy Pulp & Paper Proposed Mill Expansion, Tumut NSW, Submissions Report*, prepared by Visy Pulp and Paper Pty Ltd and dated March 2007;
 - d) the concept approval granted with respect to the Visy Tumut Mill Expansion (06_0159);
 - e) the *Statement of Commitments* prepared by Visy Pulp and Paper Pty Ltd dated 18 April 2007;
 - f) *Tumut Mill Expansion – Project Component Phasing Changes*, prepared by Visy Pulp and Paper Pty Ltd and dated 19th June 2007, and
 - g) the conditions of this approval.
 - 1.2 In the event of an inconsistency between:
 - a) the conditions of this approval and any document listed from condition 1.1a) and 1.1g) inclusive, the conditions of this approval shall prevail to the extent of the inconsistency; and
 - b) any document listed from condition 1.1a) and 1.1g) inclusive, and any other document listed from condition 1.1a) and 1.1g) inclusive, the most recent document shall prevail to the extent of the inconsistency.
2. Replacing Table 2 in condition 2.10 with the following:

Table 1 - Maximum Allowable Discharge Concentration Limits (Main Stack 2)

Pollutant	100 Percentile limit (mgm ⁻³)
Cadmium	0.5
Chlorine	100
Mercury	0.5
Nitrogen Oxides	400
Hydrogen Chloride**	50
Sulfur Dioxide**	250
Total Solid Particulates	50
Sulfuric acid mist and sulfur trioxide (as SO ₃)	20
Opacity*	20
TCDD (equivalent)*	0.1
Hydrogen Fluoride	20
Type 1 and Type 2 Substances (in aggregate)	1
TRS (as H ₂ S)	2***

* Note: The unit of measure for Opacity is %Opacity and for TCDD (equivalent) it is ng/m³.

** Note: Is the maximum allowable discharge concentration limit for the multi-fuel boiler operating on standard fuels only.

*** Note: The TRS limit is 2 mgm⁻³, except for phase 1a operation of Main Stack 2 where the limit is 3.6 mgm⁻³. Phase 1a is as described in the document listed under condition 1.1f).

3. Inserting in condition 2.10 the following:

Table 2A – Minimum Exit Velocity (Main Stack 2)

Phase**	Equipment Discharging to Stack 2	Minimum Exit Velocity (ms ⁻¹ at 750 tdsday ⁻¹)	Minimum Exit Velocity (ms ⁻¹ at 900 tdsday ⁻¹)
1a	New Recovery Boiler	18.4	22.1
1b	New Recovery Boiler and New Natural Gas Boiler	33.7*	37.4*
2	New Recovery Boiler and New Natural Gas Boiler and New Multi-Fuel Boiler	33.7*	37.4*

Note: The unit of measure tdsday⁻¹ is tonnes dry solids per day for the New Recover Boiler.

* Note: These limits may require additional acoustic controls for Stack 2.

** Note: Phases are as described in the document listed under condition 1.1f).